

Certificate Number: T-01243

Date of Issue: 25th September 2024

Client Name: St Andrews Church Rooms

Property Address: Mission Hall Lane, Sutton Poyntz, Weymouth, Dorset, DT3 6LY



## CERTIFICATE OF ROUTINE SERVICING

We hereby certify that the maintenance work carried out at the above property on the systems identified below, complies to the best of our knowledge and belief with the recommendations of the British Standards listed:

Portable Fire Extinguishers

BS 5306-3 2017

Basic Service

Technician: Howard Pocock

Signed for and on behalf of Dorset Fire Protection:



This Inspection and Servicing Certificate should be read in conjunction with the accompanying Service Report, which may include details of any Variations or Recommendations.

**Property:**  
 P-1408 St Andrews  
 Mission Hall  
 Mission Hall Lane, Sutton  
 Poyntz, Weymouth,  
 Dorset, DT3 6LY

**Client:**  
 St Andrews Church  
 Rooms

**Task:**  
 T-01243

**Issued by:**  
 Howard Pocock  
 25th September 2024

**Performed Date:**  
 24th September 2024

## Scope of Works

Portable Fire Extinguishers: Basic Service (0)

0	<b>Critical Defects</b>	A defect that renders a system inoperative.
0	<b>Non-critical Defects</b>	A system impairment not likely to critically affect the operation of the system.
0	<b>Non-conformances</b>	Missing information or incorrect feature that does not affect the system operation.
0	<b>Recommendations</b>	A modification suggested to improve the system performance.
0	<b>Informational Notes</b>	Detailed advice or general comment.

## Servicing Summary

Service	Asset	Quantity
Portable Fire Extinguishers: Basic Service	Fire Blankets	1
Portable Fire Extinguishers: Basic Service	Fire Extinguishers	3

## Maintenance

### Portable Fire Extinguishers: Basic Service

BS 5306-3 2017

Asset	Status
001 - 1.2 M x 1.2 M Fire Blanket Kitchen	PASS
001 - Foam 6.0 L Portable Fire Extinguisher Main Hall (front)	PASS
002 - Foam 6.0 L Portable Fire Extinguisher Main Hall (rear)	PASS
003 - CO2 2.0 KG Portable Fire Extinguisher Kitchen	PASS



## Signoff

Maintenance has been carried out in accordance with the relevant British Standards.

Technician	Date/Time	Accreditations	Signature
Howard Pocock	24th Sep 2024 1PM		

### Company Accreditations:

